



Shelby Energy Cooperative

® Your Touchstone Energy® Partner 

RECEIVED

APR 01 2013

PUBLIC SERVICE
COMMISSION

March 28, 2013


Director of Engineering
Public Service Commission
P.O. Box 615
Frankfort, KY 40602-0615

RE: Administrative Case No. 2006-0494

Enclosed are the original and ten (10) copies of the 2012 Distribution Reliability Report for Shelby Energy Cooperative as requested in the above order dated October 26, 2007.

Should you have any questions or need further information, please feel free to contact us.

Sincerely,




Jason Ginn
V.P. of Operations & Engineering

Enclosure

www.shelbyenergy.com

620 Old Finchville Road · Shelbyville, Kentucky 40065-1714

Shelby Co. (502)633-4420 · Trimble Co. (502)255-3260 · Henry Co. (502)845-2845



Shelby Energy
Cooperative



Your Touchstone Energy® Partner



2012 PSC Distribution Reliability Report

In regards to Administrative Case NO. 2006-00494

February 14, 2013

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 1: CONTACT INFORMATION

UTILITY NAME	1.1	<u>Shelby Energy Cooperative</u>
REPORT PREPARED BY	1.2	<u>Distribution System Solutions, Inc.</u>
E-MAIL ADDRESS OF PREPARER	1.3	<u>jtaylor.dss@fuse.net</u>
PHONE NUMBER OF PREPARER	1.4	<u>859-363-7983</u>

SECTION 2: REPORT YEAR

CALENDAR YEAR OF REPORT	2.1	<u>2012</u>
-------------------------	-----	-------------

SECTION 3: MAJOR EVENT DAYS

T_{MED}	3.1	<u>12.6</u>
FIRST DATE USED TO DETERMINE T_{MED}	3.2	<u>1-Jan-07</u>
LAST DATE USED TO DETERMINE T_{MED}	3.3	<u>31-Dec-11</u>
NUMBER OF MED IN REPORT YEAR	3.4	<u>4</u>

NOTE: Per IEEE 1366 T_{MED} should be calculated using the daily SAIDI values for the five prior years. If five years of data are not available, then utilities should use what is available until five years are accumulated.

SECTION 4: SYSTEM RELIABILITY RESULTS

Excluding MED

SAIDI	4.1	<u>92.00</u>
SAIFI	4.2	<u>0.94</u>
CAIDI	4.3	<u>97.87</u>

Including MED (Optional)

SAIDI	4.4	<u>220.13</u>
SAIFI	4.5	<u>1.24</u>
CAIDI	4.6	<u>177.52</u>

Notes:

- 1) All duration indices (SAIDI, CAIDI) are to be reported in units of minutes.
 - 2) Reports are due on the first business day of April of each year
 - 3) Reports cover the calendar year ending in the December before the reports are due.
 - 4) IEEE 1366 (latest version) is used to define SAIDI, SAIFI, CAIDI, and T_{MED}
-

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: OUTAGE CAUSE CATEGORIES

Excluding MED

CAUSE CODE DESCRIPTION		SAIDI VALUE	CAUSE CODE DESCRIPTION		SAIFI VALUE
Scheduled	5.1.1	14.27	Scheduled	5.2.1	0.13
Major Storms	5.1.2	0.00	Major Storms	5.2.2	0.00
Equipm't or Installation	5.1.3	8.01	Equipm't or Installation	5.2.3	0.06
Age or Deterioration	5.1.4	0.23	Age or Deterioration	5.2.4	0.00
Weather	5.1.5	52.87	Weather	5.2.5	0.36
Birds or Animals	5.1.6	4.94	Birds or Animals	5.2.6	0.06
Public	5.1.7	4.59	Public	5.2.7	0.04
N/A	5.1.8		N/A	5.2.8	
Unknown	5.1.9	3.50	Unknown	5.2.9	0.04
Power Supplier	5.1.10	3.62	Power Supplier	5.2.10	0.24

SECTION 6: WORST PERFORMING CIRCUITS

CIRCUIT IDENTIFIER		SAIDI VALUE	MAJOR OUTAGE CATEGORY
Sub 5 Feeder 1	6.1.1	386.86	Construction
Sub 3 Feeder 2	6.1.2	223.64	Weather / Ice
Sub 3 Feeder 1	6.1.3	223.56	Weather / Ice
Sub 13 Feeder 2	6.1.4	204.57	Lightning & Pwr Supplier
Sub 4 Feeder 3	6.1.5	204.02	Weather / Trees
Sub 2 Feeder 4	6.1.6	182.05	Equipment Fault
Sub 2 Feeder 2	6.1.7	156.48	Animal Caused Fault
Sub 12 Feeder 3	6.1.8	142.50	Animal Caused Fault
Sub 9 Feeder 1	6.1.9	120.00	Lightning
Sub 2 Feeder 5	6.1.10	118.68	Weather / Trees

CIRCUIT IDENTIFIER		SAIFI VALUE	MAJOR OUTAGE CATEGORY
Sub 2 Feeder 4	6.2.1	2.81	Equipment Fault
Sub 2 Feeder 1	6.2.2	2.35	Weather / Ice
Sub 3 Feeder 1	6.2.3	2.31	Weather / Ice
Sub 13 Feeder 2	6.2.4	2.21	Lightning & Pwr Supplier
Sub 5 Feeder 1	6.2.5	2.18	Construction
Sub 3 Feeder 2	6.2.6	2.17	Weather / Ice
Sub 9 Feeder 1	6.2.7	2.00	Lightning
Sub 2 Feeder 2	6.2.8	1.97	Animal Caused Fault
Sub 2 Feeder 5	6.2.9	1.89	Weather / Trees
Sub 3 Feeder 3	6.2.10	1.83	Lightning & Construction

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

Additional pages may be attached as necessary

SECTION 7: VEGETATION MANAGEMENT PLAN REVIEW

See attached report.

SECTION 8: UTILITY COMMENTS

See attached report.

Table of Contents

Purpose of Report.....	I
IEEE 1366 Definition of terms.....	II
Historical Data.....	III
2012 System Indices.....	IV
Outage Causes.....	V
Ten Worst Circuits.....	VI
Appendix A – Vegetation Plan	

I. Purpose of Report

This report is pursuant to the Public Service Commission's request for all electric distribution utilities to provide annual reports of reliability information as outlined in the findings from administrative case no. 2006-00494. This report documents the reliability performance of **Shelby Energy Cooperative ("Shelby")** in Shelbyville, Kentucky for the 2012 calendar year.

Results in this report will be based on indices defined in IEEE standard 1366-2003, and will be reported on both system wide levels; as well as on the circuit level for the purpose of determining the ten worst performing circuits in the Shelby system. In this analysis major event days will not be included. Major Event Days will be identified based on the Beta Method described in the IEEE 1366 standard.

II. IEEE 1366 Definition of terms

The following terms are defined according to the IEEE standard 1366 and have been used in this report.

1. SAIFI = System Average Interruption Frequency Index calculated as

$$\text{SAIFI} = \frac{\text{Total number of customer interruptions}}{\text{Total number of customers served}}$$

2. SAIDI = System Average Interruption Duration Index given in minutes & hours per year calculated as

$$\text{SAIDI} = \frac{\text{Sum of all customer interruption durations}}{\text{Total number of customers served}}$$

3. CAIDI = Customer Average Interruption Duration Index

$$\text{CAIDI} = \frac{\text{SAIDI}}{\text{SAIFI}} = \frac{\text{Sum of all customer interruption durations}}{\text{Total number of customer interruptions}}$$

T_{MED} = Major event day identification threshold value calculated as

$$T_{\text{MED}} = e^{(\alpha + 2.5\beta)} \quad \text{where}$$

α = the average of the natural logarithms of each daily SAIDI value for the year

β = the standard deviation of the natural logarithms of the daily SAIDI values

III. Historical Data

Tables III.1 and III.2 show the reliability indices for the Shelby system for the past twelve years. Table III.1 reflect all outages excluding outages caused by major storms. The Beta Method outlined in IEEE 1366 for identifying Major Event Days was not used when determining these indices. Table III.2 reflects outages where Major Event Days have been identified and omitted when determining the outage indices according to IEEE 1366.

Table III.1 Historical Indices

	SAIDI	SAIFI	CAIDI
2000	3.68	1.69	2.18
2001	2.32	1.27	1.83
2002	1.61	0.85	1.89
2003	1.30	0.76	1.71
2004	1.10	0.80	1.38
2005	1.09	0.53	2.08
2006	1.84	0.82	2.23

Table III.2 Historical Indices using IEEE 1366

	SAIDI	SAIDI	SAIFI	CAIDI	CAIDI
	in hrs	in mins		in hrs	in mins
2007	0.91	54.31	0.67	1.35	80.79
2008	1.48	89.04	0.79	1.88	112.71
2009	1.86	111.59	0.85	2.19	131.28
2010	1.57	93.93	0.72	2.17	130.46
2011	1.78	107.01	1.00	1.78	107.01

IV. 2012 System-wide Reliability Indices

All reliability indices for the Shelby system for 2012 were calculated with Major Event Days excluded. The Major Event Day Threshold (T_{MED}) was determined based on the SAIDI (in mins)/day values for 2007, 2008, 2009, 2010, and 2011 and equals **12.61** SAIDI/day. The Major Event Days (days that exceeded T_{MED}) for 2012 are identified in Table IV.1. Monthly and year total reliability indices for 2012 are shown in Table IV.2.

Table IV.1 Major Event Days

Date	Related Cause	SAIDI /day (min)
3/2/2012	Wind	33.31
7/1/2012	Lightning / Trees	33.98
7/26/2012	Lightning / Trees	25.43
7/27/2012	Lightning	35.50

Table IV.2 2012 Reliability Indices

**2012 Reliability Indices Excluding Major Event Days
By Month**

Months Totals	SAIFI	SAIDI		CAIDI
JANUARY	0.04	2.63		69.00
FEBRUARY	0.23	3.80		16.26
MARCH	0.07	13.87		185.29
APRIL	0.04	3.38		76.64
MAY	0.12	20.59		178.22
JUNE	0.07	5.33		72.17
JULY	0.10	12.75		133.49
AUGUST	0.04	2.78		72.81
SEPTEMBER	0.06	7.80		128.74
OCTOBER	0.06	6.26		109.15
NOVEMBER	0.02	1.72		89.79
DECEMBER	0.09	11.09		127.73
YEARLY TOTAL	0.94	92.00	mins	97.87
		1.53	hours	1.63


V. Outage Causes

Shelby tracks the causes of outages to the best of their ability. There are 9 main groups of cause categories. Table V.1 shows the reliability indices for each cause category group. Charts V.1 – V.3 show the percent contribution of each cause category to the overall system reliability indices.

Table V.1 Outages by Cause Codes
2012 Outages excluding Major Event Days
By Cause Codes

Cause Code	Description	No. Of Consumers	Consumer Hours	SAIFI	SAIDI	CAIDI
10's	Scheduled	1,959	3,651.88	0.13	14.27	109.77
20's	Major Storms	0	0.00	0.00	0.00	0.00
30's	Equipment or Installation	959	2,049.54	0.06	8.01	133.50
40's	Age or Deterioration	19	59.49	0.00	0.23	185.94
50's	Weather	5,558	13,534.45	0.36	52.87	146.86
60's	Birds or Animals	908	1,264.90	0.06	4.94	82.33
70's	Public	676	1,173.78	0.04	4.59	114.75
99	Unknown	569	895.98	0.04	3.50	87.50
00	Power Supplier	3,746	927.32	0.24	3.62	15.09

Chart V.1 SAIFI by Cause Code



V. Outage Causes - continued

Chart V.2 SAIDI by Cause Code







Chart V.3 CADI by Cause Code



VI. Ten Worst Circuits

The reliability indices were calculated for each feeder for 2012, and the ten worst performing feeders for SAIFI and SAIDI were identified. Each feeder was analyzed as its own "system" in that only the consumers served on a given feeder were used in the calculation of the index for that feeder. Tables VI-1 through VI-2 on the following pages show the results of the feeder analysis for each index listed from worst to best in reliability.

Weather events were the main cause affecting the reliability of Shelby Energy's distribution system. Shelby Energy strives to design, maintain, and operate its distribution system to minimize outage times and affected members due to adverse weather conditions.

Shelby Energy, in direct cooperation with our power supplier, EKP continue to install wild life guards and insulated cover up material in substations and on distribution equipment where electrical clearances are close. Shelby has recently begun utilizing insulated jumper wire for all transformers and other equipment installed on the system.

Circuits where poor performance can be attributed to material/equipment faults continue to be evaluated for replacement and/or up-grade.

Substation Reference Guide

<u>Sub Number</u>	<u>Sub Name</u>	<u>Location</u>
1	Logan 1	Shelby
2	Clay Village	Shelby
3	New Castle	Henry
4	Campbellsburg	Henry
5	Bedford	Trimble
6	Southville	Shelby
7	Milton	Trimble
8	Budd	Shelby
9	Bekeart 1	Shelby
10	Logan 2	Shelby
11	Jericho	Henry
12	Bekeart 2	Shelby
13	Long Run	Shelby
14	Bekeart 3	Shelby

**Table VI.1 Circuits with 10 worst SAIFI indices in grey
Reliability Rankings from Greatest to Least
By SAIFI**

Substation	Feeder	No. Of Consumers Out	Consumer Hours	No. Of Consumers on Feeder	SAIFI	Major cause
2	4	654	706.97	233	2.81	Equipment Fault
2	1	902	717.17	384	2.35	Weather / Ice
3	1	729	1173.68	315	2.31	Weather / Ice
13	2	953	1472.89	432	2.21	Lightning & Pwr Supplier
5	1	1337	3946.01	612	2.18	Construction
3	2	1195	2050.05	550	2.17	Weather / Ice
9	1	2	2.00	1	2.00	Lightning
2	2	801	1058.82	406	1.97	Animal Caused Fault
2	5	498	520.22	263	1.89	Weather / Trees
3	3	861	814.34	470	1.83	Lightning & Construction
7	3	373	381.49	224	1.67	
12	3	13	19.00	8	1.63	
4	3	694	1530.16	450	1.54	
12	2	7	9.25	5	1.40	
2	3	1465	1345.24	1088	1.35	
7	4	430	825.42	422	1.02	
13	1	313	342.54	309	1.01	
4	1	548	1040.02	665	0.82	
1	2	117	172.30	145	0.81	
5	4	222	341.58	293	0.76	
5	2	266	429.16	359	0.74	
4	4	285	482.96	461	0.62	
11	3	265	367.21	429	0.62	
5	3	313	679.82	520	0.60	
11	2	252	325.30	491	0.51	
1	3	296	583.38	610	0.49	
6	3	193	510.07	459	0.42	
4	2	222	351.30	615	0.36	
1	4	140	383.71	396	0.35	
7	2	161	246.98	662	0.24	
6	2	52	89.60	235	0.22	
10	1	176	290.84	857	0.21	
6	1	230	415.87	1160	0.20	
11	1	125	162.27	696	0.18	
7	1	6	10.50	89	0.07	
8	1	0	0.00	1	0.00	
9	2	0	0.00	3	0.00	
12	1	0	0.00	0	0.00	
14	2	0	0.00	2	0.00	

Table VI.2 Circuits with 10 worst SAIDI indices in grey

**Reliability Rankings from Greatest to Least
By SAIDI**

Substation	Feeder	No. Of Consumers Out	Consumer Hours	No. Of Consumers on Feeder	SAIDI in mins	SAIDI in hours	Major cause
5	1	1337	3946.01	612	386.86	6.45	Construction
3	2	1195	2050.05	550	223.64	3.73	Weather / Ice
3	1	729	1173.68	315	223.56	3.73	Weather / Ice
13	2	953	1472.89	432	204.57	3.41	Lightning & Pwr Supplier
4	3	694	1530.16	450	204.02	3.40	Weather / Trees
2	4	654	706.97	233	182.05	3.03	Equipment Fault
2	2	801	1058.82	406	156.48	2.61	Animal Caused Fault
12	3	13	19.00	8	142.50	2.38	Animal Caused Fault
9	1	2	2.00	1	120.00	2.00	Lightning
2	5	498	520.22	263	118.68	1.98	Weather / Trees
7	4	430	825.42	422	117.36	1.96	
2	1	902	717.17	384	112.06	1.87	
12	2	7	9.25	5	111.00	1.85	
3	3	861	814.34	470	103.96	1.73	
7	3	373	381.49	224	102.18	1.70	
4	1	548	1040.02	665	93.84	1.56	
5	3	313	679.82	520	78.44	1.31	
2	3	1465	1345.24	1088	74.19	1.24	
5	2	266	429.16	359	71.73	1.20	
1	2	117	172.30	145	71.30	1.19	
5	4	222	341.58	293	69.95	1.17	
6	3	193	510.07	459	66.68	1.11	
13	1	313	342.54	309	66.51	1.11	
4	4	285	482.96	461	62.86	1.05	
1	4	140	383.71	396	58.14	0.97	
1	3	296	583.38	610	57.38	0.96	
11	3	265	367.21	429	51.36	0.86	
11	2	252	325.30	491	39.75	0.66	
4	2	222	351.30	615	34.27	0.57	
6	2	52	89.60	235	22.88	0.38	
7	2	161	246.98	662	22.38	0.37	
6	1	230	415.87	1160	21.51	0.36	
10	1	176	290.84	857	20.36	0.34	
11	1	125	162.27	696	13.99	0.23	
7	1	6	10.50	89	7.08	0.12	
8	1	0	0.00	1	0.00	0.00	
9	2	0	0.00	3	0.00	0.00	
12	1	0	0.00	0	0.00	0.00	
14	2	0	0.00	2	0.00	0.00	

APPENDIX A

SHELBY ENERGY COOPERATIVE
620 Old Finchville Road
Shelbyville, KY

VEGETATION MANAGEMENT PLAN (VMP)

Shelby Energy Cooperative (“Shelby”) is an electric distribution system serving ten (10) counties in north-central Kentucky: Shelby, Henry, Trimble, Carroll, Owen, Oldham, Jefferson, Franklin, Spencer, and Anderson. The system consists of approximately 15,379 meters / accounts and approximately 1,831 miles of overhead and underground primary conductor. Shelby has approximately 315 miles of secondary and services. Members are served by fourteen (14) substations that are owned and operated by East Kentucky Power Cooperative with headquarters in Winchester, KY. An attachment showing the service territory and substations for Shelby is included (Exhibit 1).

Vegetation management (VM) plays an integral role in accomplishing the mission statement for Shelby Energy Cooperative:

“Shelby Energy Cooperative will provide safe, reliable and cost-effective energy service, while preserving our environment. Our mission is to educate members, employees, and the public with knowledge and tools to use energy safely and efficiently to enhance their quality of life.”

Maintaining effective VM is a major factor in promoting a safer environment within Shelby’s certified territory. VM reduces the possibility of accidental contact with energized power lines thus providing safer conditions for the public, for employees and for contractors. Reliability and power quality enhancements are also afforded by proper VM.

RIGHT OF WAY (ROW) CLEARING CYCLE

Shelby uses a clearing cycle of four (4) to five (5) years that combines ROW trimming, spraying and mowing. The variance of four (4) to five (5) years is used to adjust the clearing cycle based on yearly growing conditions. This in turn helped Shelby prioritize

the circuits to be managed. Hourly contract cutting crews (crews) are utilized by Shelby with no less than one (1) crew working year around as weather and/or work permits.

Routinely one (1) spray crew is used several months during the summer season to control undergrowth in areas where the ROW was trimmed/cut the previous year. The spraying is focused in cross country areas where high undergrowth problems are recognized. On average, 350 circuit-miles are cleared of vegetation by trimming, cutting and/or spraying annually. Shelby elected in 2012 to bid feeders to different tree service companies. These companies utilize their employees along with various equipment to ensure the ROW is maintained in the manner we require.

These crews and equipment enables Shelby to cover more rough terrain and clear ROW issues in many cross country locations. Shelby complies with the RUS ROW Clearing Guide ~ M1.30G.

PERFORMANCE OF MAINTENANCE

The ROW clearing cycle is established and adjusted as needed to manage the ROW cycle and maintain a high standard of service, quality and reliability. Trouble areas receive timely attention to resolve associated outage or service issues as discovered. Shelby O&E personnel and contractors report problems during their routine work and patrolling efforts to define locations requiring attention to ROW issues. These issues are handled on a case-by-case basis depending upon the severity of the issue.


RELIABILITY CRITERIA AND REPORTS

Shelby's Operations and Engineering (O&E) employees monitor daily, monthly, and annual outage reports and service requests initiated by employees, contractors and cooperative members. This information is reviewed to determine if trends exist indicating a deterioration of service quality or reliability within any specific area. In addition, Shelby utilizes the services of a professional engineering consultant to review outage data and assist in resolving service quality or reliability issues.

PLAN EVALUATION

Shelby regularly monitors outages to determine their underlying cause(s). These findings are reviewed monthly, annually, and over a rolling five (5) year period to determine if trending indicates a decline in service quality or reliability is developing within an area of the cooperative's system. Employees of Shelby's O&E department work with a professional engineering consultant to calculate, review, and evaluate standard reliability indices of SAIFI, SAIDI, and CAIDI. Shelby's O&E personnel and its professional engineering consultant continuously monitor and verify that reliability issues are resolved in such a manner that best benefits the members of the cooperative.

Exhibit # 1



SHELBY ENERGY COOPERATIVE SERVICE AREA

Exhibit # 2

RIGHT-OF-WAY CLEARING SPECIFICATIONS

The right-of-way shall be prepared by removing trees, clearing underbrush, and trimming trees so that the right-of-way is cleared close to the ground and to the width specified. However, low growing shrubs, which will not interfere with the operation or maintenance of the line, shall be left undisturbed if so directed by the owner. Slash may be chipped and blown on the right-of-way if so specified.

The landowner's written permission shall be received prior to cutting trees outside of the right-of-way. Trees fronting each side of the right-of-way shall be trimmed symmetrically unless otherwise specified. Dead trees beyond the right-of-way which would strike the line in falling shall be removed. Leaning trees beyond the right-of-way which would strike the line in falling and which would require topping if not removed, shall either be removed or topped, except that shade, fruit, or ornamental trees shall be trimmed and not removed, unless otherwise authorized.

Exhibit #2

